

Certificate of Compliance

Certificate: 2175983 **Master Contract:** 151933

Project:

2175983

Date Issued:

2009/05/17

Issued to:

Killark Electric Manufacturing Co.

3940 Martin Luther King Dr

St. Louis, MO 63113

USA

Attention: Thomas J. Michalski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by:

D. Somma, C.E.T.

Authorized by: Patricia Pasemko, Operations

Manager

Latinia Pasent)

PRODUCTS

CLASS 4418 03 - CONDUIT FITTINGS - Fittings - For Hazardous Locations

CLASS 4418 83 - CONDUIT FITTINGS - Fittings - For Hazardous Locations - Certified to

US Standards

CLASS 4418 03 – CONDUIT FITTING –Fittings for Metal Conduit-For Hazardous Locations



Certificate: 2175983 Master Contract: 151933

Project: 2175983 **Date Issued:** 2009/05/17

Class I, Groups C and D; Class II, Groups E, F and G; Class III:

• Flame Arrestor – KB1FA25, KB1FAM16, KBM20FA25 & KBM20FAM16

CLASS 4418 83 – CONDUIT FITTING – Fittings for Metal Conduit-For Hazardous Locations - Certified to US Standards

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III:

• Flame Arrestor – KB1FA25, KB1FAM16, KBM20FA25 & KBM20FAM16

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91 - General Requirements

CAN/CSA-C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F and G Hazardous

Locations - Industrial Products

CAN/CSA-C22.2 No. 30-M1986 - Explosion-Proof Enclosures for use in Class I, Hazardous Locations

ANSI/UL Standard 1203 (4th edition) - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

MARKINGS

The fitting is rolled stamped on the body of the fitting with the following information:

- Manufacturer's name, Trade Mark, File Number or Master Contract Number
- Catalogue number
- Hazardous location rating designation
- The CSA Monogram with C US indicator
- Trade Size