

1



EU TYPE-EXAMINATION CERTIFICATE

2 Component intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 13ATEX1196U** Issue: **3**

4 Component: Type R & RE Series Reducers, Type CUP & PLUG Series Plugs and Type

AN & AN-xS Series Conduit Nipples

5 Applicant: Killark, A Div. of Hubbell Inc. (Delaware)

6 Address: 3940 Martin Luther King Drive

St. Louis Missouri 63113

United States

7 This component and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

Sira Certification Service, notified body number 0518 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

IEC 60079-0:2017 Ed.7 EN 60079-1:2014 IEC 60079-7:2015 Ed 5.1

EN 60079-31:2014

The above list of documents may detail standards that do not appear on the UKAS Scope of Accreditation, but have been added through Sira's flexible scope of accreditation, which is available on request.

- The sign 'U' is placed after the certificate number to indicate that the product assessed is a component and may be subject to further assessment when incorporated into equipment. Any schedule of limitations are listed in the schedule to this certificate.
- 11 This EU type-examination certificate relates only to the design and construction of the specified component. If applicable, further requirements of this Directive apply to the manufacture and supply of this component.
- 12 The marking of the component shall include the following:

 $\langle E_{\rm X} \rangle$

II 2 G D Ex db IIC Gb Ex eb IIC Gb Ex tb IIIC Db

Ta = -50°C to +70°C

Project Number 70179043

This certificate and its schedules may only be reproduced in its entirety and without change.

C Ellaby Deputy Certification Manager

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom





EU TYPE-EXAMINATION CERTIFICATE

Sira 13ATEX1196U Issue 3

13 **DESCRIPTION OF COMPONENT**

Type R & RExxS Series Reducers:

The Type R and RExxS Series Reducers comprise a hollow hexagonal body, partly threaded at each end, one end having a male thread and the other a female thread. The Reducers are used to convert an existing threaded cable entry aperture to a different thread form and/or size.

The Type R and RExxS Series Reducers have an IP 66 ingress protection rating in accordance with EN 60529.

The Reducers may be machined with NPT thread forms in sizes and materials as follows:

Sizes:	Materials of manufacture:
3/8-18 NPT	A1 = Aluminium, 6061-T6, 6061-T651
1/2"-14 NPT	A2 = Aluminium, AA356-T6
34"-14 NPT	A3 = Aluminium, Modified A413.1 Alloy Per Killark Spec. MA-0105
1"-11 ½ NPT	S = Zinc Electroplated Steel (12L14); or Zinc Electroplated Steel (12L14-SA)
1 ¼"-11 ½ NPT	S3 = SS-303 Grade
2"-11 ½ NPT	S4 = SS-304 Grade
2 1/2"-8 NPT	S6 = SS-316 Grade
3"-8 NPT	
3 1/2"-8 NPT	
4"-8 NPT	

Surface coating

The products may additionally be metallic plated with Zinc (0.008 mm thick max.) to suit the application.

Type CUP & PLUG Series:

The CUP & PLUG series comprise a cylindrical body, threaded with a male thread. They are intended to fill unused cable entries in associated apparatus.

The CUP & PLUG series have an IP 66 ingress protection rating in accordance with EN 60529.

The products are manufactured with the following external profiles and assigned the following prefix type designations:

CUP-250 - CUP-6; Hexagonal socket recess PLUG-250 - PLUG-3; Hexagonal socket recess PLUG-4 - PLUG-6; Square socket recess CUP-7 - CUP-8 & PLUG-7-PLUG-10; Cross (X) recess

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom





EU TYPE-EXAMINATION CERTIFICATE

Sira 13ATEX1196U Issue 3

The CUP & PLUG series may be machined with NPT thread forms in sizes and materials as follows:

Sizes:	Materials of manufacture:
1/4"-18 NPT	CUP – Series
3/8"-18 NPT	(blank); A1 = Aluminium, 6061-T6, 6061-T651
1/2"-14 NPT	(blank); A2 = Cast Aluminium, AA356-T6
3/4"-14 NPT	S3 = SS-303 Grade
1"-11 ½ NPT	S4 = SS-304 Grade
1 ¼"-11 ½ NPT	S6 = SS-316 Grade
1 ½"-11 ½ NPT	
2"-11 ½ NPT	PLUG Series:
2 1/2"-8 NPT	(blank) = Zinc Electroplated Steel (12L14) or Zinc Electroplated Steel (12L14-SA)
3"-8 NPT	S3 = SS-303 Grade
3 1/2"-8 NPT	S4 = SS-304 Grade
4"-8 NPT	S6 = SS-316 Grade

Type AN & AN-xS Series Conduit Nipples:

The AN & AN-xS Series Conduit Nipples comprise a cylindrical straight body, with NPT male threads on each end. They are used for the protection of wire conductors and intended to connect conduit to cast hubs on drilled and tapped conduit openings.

The AN & AN-xS Series Conduit Nipples have an IP 66 ingress protection rating in accordance with EN 60529.

The Nipples may be threaded in sizes and materials as follows:

Sizes:	Materials of manufacture:
1/2"-14 NPT	(blank) = Aluminium, 6063 alloy
34"-14 NPT	S = Zinc Electroplated Rigid Steel Conduit
1"-11 ½ NPT	S3 = SS-303 Grade
1 ¼"-11 ½ NPT	S4 = SS-304 Grade
2"-11 1/2 NPT	S6 = SS-316 Grade
2 1/2"-8 NPT	
3"-8 NPT	
3 1/2"-8 NPT	
4"-8 NPT	

Variation 1 - This variation introduced the following change:

i. The introduction of a 3"-1¼" NPT reducer, Type reference R-84, to the existing range.

Variation 2 - This variation introduced the following changes:

- i. Change of the notified body responsible for quality on the marking from 0539 to a drawing note.
- ii. The inclusion of the $1\frac{1}{2}$ "- $11\frac{1}{2}$ " NPT reducer, Type reference R-51, R-52, R-53 and R-54, to the existing range.
- iii. Correction of administrative error on the Nipple scheduled drawing 23541.
- iv. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, EN 60079-1:2007, EN 60079-7:2007 and EN 60079-31:2009 were replaced by EN 60079-1:2014, EN 60079-7:2015 and EN 60079-31:2014. The markings have been updated in accordance with the latest standards.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom





EU TYPE-EXAMINATION CERTIFICATE

Sira 13ATEX1196U Issue 3

Variation 3 - This variation introduced the following changes:

- i. A change to the upper ambient temperature of components, from +60°C, to +70°C was approved.
- ii. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, EN 60079-0:2012/A11:2013 and EN 60079-7:2015 were replaced by IEC 60079-0:2017 Ed.7 and IEC 60079-7:2015 Ed 5.1. The markings have been updated in accordance with the latest standards.

14 **DESCRIPTIVE DOCUMENTS**

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report number	Comment
0	27 June 2013	R28593A/00	The release of the prime certificate.
1	31 January 2014	R32724A/00	The introduction of Variation 1.
2	19 December 2017	R70159950A	 This Issue covers the following changes: EC-Type Examination Certificate in accordance with 94/9/EC updated to EU-Type Examination Certificate in accordance with Directive 2014/34/EU. (In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC-Type Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.) The introduction of Variation 2
3	17 May 2018	R70179043A	The introduction of Variation 3.

15 **SCHEDULE OF LIMITATIONS**

- 15.1. The Stopping Plugs and Blanking elements shall not be used in conjunction with an adapter or reducer when installed in a flameproof enclosure.
- 15.2. Nipples and Reducers shall not to be used for the direct inter-connection of enclosures.
- 15.3. Only one Nipple or Reducer is to be used with any single cable entry on the associated equipment.
- 15.4. The Nipples, Reducers and Plugs are for threaded entries only.
- 15.5. The interfaces between the male thread of the adaptor/reducer and an associated enclosure and between the female thread of the adaptor/reducer and the cable entry device cannot be defined. Therefore it is the installer's responsibility to ensure that the appropriate ingress protection level is maintained at these interfaces.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom





EU TYPE-EXAMINATION CERTIFICATE

Sira 13ATEX1196U Issue 3

- 15.6. For the nipples, installation is to be in accordance with the manufacturer's installation manual, ensuring correct thread engagement and torque is applied to ensure threads are undamaged. Installation in accordance to EN 60079-14 is also to be followed.
- 16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

- 17 **CONDITIONS OF MANUFACTURE**
- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of Sira Certificates.
- 17.2 Holders of EU type-examination certificates are required to comply with the production control requirements defined in Article 13 of directive 2014/34/EU.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Certificate Annexe

Certificate Number: Sira 13ATEX1196U



Series Plugs and Type AN & AN-xS Series

Conduit Nipples

Applicant: Killark, A Div. of Hubbell Inc. (Delaware)

Issue 0

Drawing No.	Sheets	Rev.	Date (Sira Stamp)	Title
B-23541	1 of 1	Α	17 Jun 13	AN & AN-XS Series Close Nipples for IECEx/ATEX
				Certification
D-23389	1 of 1	Α	17 Jun 13	CUP & PLUG Series Stoppers (plugs) for IECEx/ATEX
				Certification
D-23534	1 of 1	Α	17 Jun 13	R & RExxS Series Reducer Bushings for IECEx/ATEX
				Certification

Issue 1

Drawing No.	Sheets	Rev.	Date (Sira stamp)	Title
D-23534	1 of 1	В	22 Jan 14	R & RExxS Series Reducer Bushings for IECEx/ATEX
				Certification

Issue 2

Drawing No.	Sheets	Rev.	Date (Sira Stamp)	Title
D-23389	1 of 1	В	24 Oct 17	Cup & Plug Series Stoppers (Plugs) for IECEx/ATEX
				Certification
B-23541	1 of 1	В	24 Oct 17	AN & AN-xS Series Close Nipples for IECEx/ATEX
				Certification
D-23534	1 of 1	С	24 Oct 17	R & RExxS Series Reducer Bushings for IECEx/ATEX
				Certification

Issue 3

Drawing No.	Sheets	Rev.	Date (Sira Stamp)	Title
D-23389	1 of 1	С	02 May 18	CUP & Plug Series Stoppers (Plugs) for IECEx/ATEX
				Certification
B-23541	1 of 1	С	02 May 18	AN & AN-xS Series Close Nipples for IECEx/ATEX
				Certification
D-23534	1 of 1	D	02 May 18	R & RExxS Series Reducer Bushings for IECEx/ATEX
			,	Certification

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom