



# Certificate of Compliance

**Certificate:** 2596060

**Master Contract:** 171050

**Project:** 2596060

**Date Issued:** April 2, 2013

**Issued to:** R. Stahl Schaltgeraete GmbH

Am Bahnhof 30  
Waldenburg, 74638  
Germany  
Attention: Thomas Minde

*The products listed below are eligible to bear the CSA Mark shown*



*Jelena Dzeletovic*

**Issued by:** Jelena Dzeletovic

## **PRODUCTS**

**CLASS 3218 01** - INDUSTRIAL CONTROL EQUIPMENT - Custom Built - For Hazardous Locations

Ex e II ; IP66; Suitable -50 °C to 40 °C.

Class II, Division 1 and 2, Groups EFG, Class III;

CSA Enclosure Type 3, 4, 4x;

- 8146/5 Explosion Protected Control/Distribution Stations.

## **Notes:**

(1) The above equipment may also bear the optional marking shown below.

(2) The 8146 Control Station can also be fitted with blue terminals for use in Intrinsically Safe circuits.

## **APPLICABLE REQUIREMENTS**

The following standards were used in the evaluation of the products covered under this Certificate:



**Certificate:** 2596060

**Master Contract:** 171050

**Project:** 2596060

**Date Issued:** April 2, 2013

---

Technical Information Letter TIL E-24 - Clarification of Marking Requirements for Electrical Equipment Certified to the requirements of IEC 79 Series Standards, C22.2 Series Standards, or both.

CAN/CSA - No. 60079-0-11 - Electrical Apparatus for Explosive Gas Atmospheres Part 0: General Requirements

CAN/CSA E60079-1-02 - Electrical Apparatus for Explosive Gas Atmospheres - Part 1: Flameproof Enclosures "d"-

CAN/CSA - No. 60079-7-12 - Electrical Apparatus for Explosive Gas Atmospheres - Part 7: Increased Safety "e"-

CAN/CSA E61241-1-1:02 - Electrical apparatus for use in the presence of combustible dust.